

# Installation Operation Maintenance Instruction Addendum

## VFD Programming Setup

Location	Code #	Code Description	Setting
BASIC SETUP	P102	Min. Frequency	6.2Hz
	P103	Max. Frequency	60Hz
	P178	Frequency Multiplier	1.67 (100% @60Hz)
VECTOR SETTINGS	P302	Motor Rated Voltage	230 VAC
	P303	Motor Rated Current	2 Amps
	P304	Motor Rated Frequency	60Hz
	P305	Motor Rated Speed	1725 RPM



## VFD- Vector Series

By Lenze A/C Tech

Model#: ESV751N01SXE

Serial#: \_\_\_\_\_



72-001-02-1 Rev A



BLACK  
LINE